



1 SCOPE

This document details the application of SOP 275 issued by the Electricity Association.

2 ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
August 2002	1	David Naylor	Initial Issue 2 Page Document

3 ISSUE AUTHORITY

Author	Owner	Issue Authority
David Naylor Senior Project Engineer	Alastair Ferguson Section Head Engineering Support	Eric Leavy Engineering & Transmission Operations Manager



4 SOP DETAILS

TYPE : Alstom Saturn type RT RMU **20kA Version only**

ORIGINATING REC : United Utilities

DATE : 18/05/01

NO. INSTALLED IN MANWEB: No 20kA units in Manweb

STATUS : Restriction: No live operation. Access to substations restricted.

REASON: Disruptive failure due to internal arc

UPDATE:

REMEDIAL ACTION: Inspection of failed unit to be undertaken by manufacturer. Remedial action to be decided.