



**1 SCOPE**

This document details the application of SOP 285 issued by the Electricity Association.

**2 ISSUE RECORD**

**This is a controlled maintained document**

**All copies printed via the Intranet or photocopied will be deemed uncontrolled.**

<b>Issue Date</b>	<b>Issue No</b>	<b>Author</b>	<b>Amendment Details</b>
August 2002	1	David Naylor	Initial Issue 2 Page Document

**3 ISSUE AUTHORITY**

<b>Author</b>	<b>Owner</b>	<b>Issue Authority</b>
David Naylor Senior Project Engineer	Alastair Ferguson Section Head Engineering Support	Eric Leavy Engineering & Transmission Operations Manager  .....



**4 SOP DETAILS**

**TYPE :** Alstom (GEC) Switch type IB5, 11kV

**ORIGINATING REC :** GPU Power (MEB)

**DATE :** 27/11/2001

**NO. INSTALLED IN MANWEB:** None.

**STATUS :** Restriction: Unit to be made not live before operation, until oil level confirmed to be correct.

**REASON:** Unit found to not have been filled with oil on original installation. No switchgear defect.

**UPDATE:**

**REMEDIAL ACTION:**