

1. SCOPE

This document details the application of SOP 299 issued by the Electricity Association.

2. ISSUE RECORD

This is a controlled maintained document.

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
November 2002	1	D.W. Naylor	Initial issue 2 page document

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Naylor Senior Project Engineer	Alastair Ferguson Section Head Engineering Support	Eric Leavy Engineering & Transmission Operations Manager

4. SOP DETAILS

TYPE : Lucy type CF1 11kV switch fuse RMU

ORIGINATING DNO : Scottish & Southern Energy

DATE : 5 November 2002

NO. INSTALLED IN POWER SYSTEMS SOUTH: 0

NO. INSTALLED IN POWER SYSTEMS NORTH: 0

STATUS : Ban on live operation.
Restriction on access to substations that contain this unit.

REASON: Failure of unit attributed to severe surface discharge within unit.

UPDATE:

REMEDIAL ACTION: Scottish & Southern Energy intend to remove all units from their network.