



1. SCOPE

This document details the application of SOP 305 issued by the Electricity Association.

2. ISSUE RECORD

This is a controlled maintained document.

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
September 2003	1	D.W. Naylor	Initial issue 2 page document

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Naylor Senior Project Engineer	Alastair Ferguson Section Head Engineering Support	Alastair Ferguson Section Head Engineering Support

4. SOP DETAILS

TYPE : ABB type VD4/ZS1 11kV circuit breaker

ORIGINATING DNO : Aquila Networks Services Ltd

DATE : 4 August 2003

NO. INSTALLED IN POWER SYSTEMS NORTH: 0

NO. INSTALLED IN POWER SYSTEMS SOUTH: 0

STATUS : RESTRICTION: Opening and closing of these circuit breakers is limited to remote operation.
Access to switchrooms containing this equipment limited to the minimum number of persons and the minimum amount of time required to facilitate essential works only.
Access for isolation of moving portion to be achieved under access limitations above.

REASON: Failure of band joint lead to catastrophic failure of complete switchboard.

UPDATE:

REMEDIAL ACTION: