

1. SCOPE

This document details the application of SOP 320 issued by Energy Networks Association

2. ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
September 2005	1	David Walker	Initial issue

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Walker Technical Support Engineer	Alastair Ferguson Plant Engineering Manager	Andy Huthwaite Engineering & Transmission Operations Manager

4. SOP DETAILS

TYPE: BTH JB721 11KV Circuit Breaker

ORIGINATING DNO: EDF Energy

DATE: 14th of October 2004

NO. INSTALLED IN POWER SYSTEMS NORTH: 0

NO. INSTALLED IN POWER SYSTEMS SOUTH: 0

STATUS: 1. No live switching of units associated with RMU's
2. Operation via remote control for units at Primary Sub-stations.

SPPS Application: No units of this type on the SP T&D network.

REASON: Discovery of broken contact spring.

UPDATE:

REMEDIAL ACTION: