

**1. SCOPE**

This document details the application of SOP 322 issued by Energy Networks Association

**2. ISSUE RECORD**

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

<b>Issue Date</b>	<b>Issue No</b>	<b>Author</b>	<b>Amendment Details</b>
September 2005	1	David Walker	Initial issue

**3. ISSUE AUTHORITY**

<b>Author</b>	<b>Owner</b>	<b>Issue Authority</b>
David Walker Technical Support Engineer	Alastair Ferguson Plant Engineering Manager	Andy Huthwaite Engineering & Transmission Operations Manager .....

**4. SOP DETAILS**

**TYPE:** GEC 11KV VMX Circuit Breaker

**ORIGINATING DNO:** Defence Estates

**DATE:** 11<sup>th</sup> of November 2004

**NO. INSTALLED IN POWER SYSTEMS NORTH:** 13

**NO. INSTALLED IN POWER SYSTEMS SOUTH:** 1008

**STATUS:** Remote operation only.

**SPPS Application:** It is not considered appropriate to apply this SOP within PowerSystems. See reason below

**REASON:** Disruptive failure of VMX CB due to partial discharge activity caused by incorrect installation at Defence Estates site.

**UPDATE:**

**REMEDIAL ACTION:**