

**1. SCOPE**

This document details the application of SOP 327 issued by Energy Networks Association

**2. ISSUE RECORD**

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

<b>Issue Date</b>	<b>Issue No</b>	<b>Author</b>	<b>Amendment Details</b>
October 2005	1	David Walker	Initial issue

**3. ISSUE AUTHORITY**

<b>Author</b>	<b>Owner</b>	<b>Issue Authority</b>
David Walker Technical Support Engineer	Alastair Ferguson Plant Engineering Manager	Andy Huthwaite Engineering & Transmission Operations Manager .....

**4. SOP DETAILS**

**TYPE:** ABB Circuit Breaker – VD4 Uniflex

**ORIGINATING DNO:** EDF Energy

**DATE:** 14<sup>th</sup> of October 2005

**NO. INSTALLED IN POWER SYSTEMS NORTH:** 0

**NO. INSTALLED IN POWER SYSTEMS SOUTH:** 0

**STATUS:** All switching must be undertaken remotely with nobody present within the Substation.

**SPPS Application:** No units of this type on the SP T&D network. This SOP for information only.

**REASON:** Failure of HV Cable Box due to partial discharge activity.

**UPDATE:**

**REMEDIAL ACTION:** None required.