

## 1. SCOPE

This document details the application of SOP 330 (Applicable to Johnson & Philips FS Switch) issued by Energy Networks Association.

## 2. ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
January 2006	1	David Walker	Initial issue

## 3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Walker Technical Support Engineer	Alastair Graham Engineering Risk Control Section Head	Alastair Ferguson Plant Engineering Manager  .....

#### 4. SOP DETAILS

**TYPE:** Johnson & Philips FS Switch.

**ORIGINATING DNO:** Central Networks

**DATE:** 5th of January 2006

**NO. INSTALLED IN POWER SYSTEMS NORTH:** 0

**NO. INSTALLED IN POWER SYSTEMS SOUTH:** 0

**STATUS:** 1. No live operation.

**SPEN Application:** No units of this type on the SP T&D network.

**REASON:** Reducing number of units on the network coupled with increased operator unfamiliarity with units.

**UPDATE:**

**REMEDIAL ACTION:** No action required.