

1. SCOPE

This document details the application of SOP 331 (Applicable to Mid Central Electric, Pole Mounted VT) issued by Energy Networks Association.

2. ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
January 2006	1	David Walker	Initial issue

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Walker Technical Support Engineer	Alastair Graham Engineering Risk Control Section Head	Alastair Ferguson Plant Engineering Manager

4. SOP DETAILS

TYPE: Mid Central Electric Pole Mounted VT.

ORIGINATING DNO: Central Networks

DATE: 9th of January 2006

NO. INSTALLED IN POWER SYSTEMS NORTH: 0

NO. INSTALLED IN POWER SYSTEMS SOUTH: 0

STATUS: No connection of MCE pole mounted VT's using live line techniques.

SPEN Application: No units of this type on the SP T&D network.

REASON: Failure of pole mounted VT on connection using live line techniques.

UPDATE:

REMEDIAL ACTION: No action required.