

## 1. SCOPE

This document details the application of SOP 333 (Applicable to Mid Central Electric PMVT) issued by Energy Networks Association.

## 2. ISSUE RECORD

This is a controlled maintained document

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
May 2006	1	David Walker	Initial issue

## 3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Walker Technical Support Engineer	Alastair Graham Engineering Risk Control Section Head	Alastair Ferguson Plant Engineering Manager .....

#### 4. SOP DETAILS

**TYPE:** Mid Central Electric Pole Mounted VT – 11/.110 KV 500VA

**ORIGINATING DNO:** Central Networks

**DATE:** 14th of April 2006

**NO. INSTALLED IN POWER SYSTEMS NORTH:** 0

**NO. INSTALLED IN POWER SYSTEMS SOUTH:** 0

**STATUS:** Local disconnection by live line techniques is not permitted if there is no LV output from the PMVT.

**SPEN Application:** No units of this type on the SP T&D network. This SOP is for information only.

**REASON:** Possibility of injury whilst carrying out live line disconnection of faulty PMVT.

**UPDATE:**

**REMEDIAL ACTION:** None required.