

1. SCOPE

This document details the application of SOP 2006/0338/00 (Applicable to Dennis Single-way LV Fuse Cabinet) issued by the Energy Networks Association.

2. ISSUE RECORD

This is a controlled maintained document.

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
Nov 2006	1	David Walker	

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Walker Senior Project Engineer	Alastair Ferguson Plant Engineering Manager	Stephen Stewart. Acting Chief Engineer

4. SOP DETAILS

EQUIPMENT TYPE:	Dennis Single-way LV Fuse Cabinet
ORIGINATING DNO	Scottish & Southern Energy
DATE:	27/09/2006
NUMBER INSTALLED IN ENERGY NETWORKS NORTH:	TBA
NUMBER INSTALLED IN ENERGY NETWORKS SOUTH:	TBA
REASON:	The insertion of a fuse onto a potential LV fault resulted in a busbar flashover.
STATUS IN INITIATING DNO:	All affected units will be fitted with a label to the outside cover and below the MDI's stating 'FUSES MUST ONLY BE INSERTED WITH THE LV DEAD'.
SPEN APPLICATION:	It is not considered appropriate to apply this SOP within EnergyNetworks, our existing policy of restoring supply to a potential LV fault using a Fusemate will continue.
UPDATE:	
REMEDIAL ACTION:	None