

## 1. SCOPE

This document details the application of SOP 2007/0343/00 (Applicable to Brush HSRSD tap changer) issued by the Energy Networks Association.

## 2. ISSUE RECORD

This is a controlled maintained document.

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
May 2007	1	Russell Hamilton	

## 3. ISSUE AUTHORITY

Author	Owner	Issue Authority
Russell Hamilton Senior Project Engineer	Alastair Ferguson Plant Engineering Manager	Jim Sutherland. Chief Engineer  .....

#### 4. SOP DETAILS

<b>EQUIPMENT TYPE:</b>	Brush HSRSD Tap Changer
<b>ORIGINATING DNO</b>	Central Networks
<b>DATE:</b>	11/05/07
<b>NUMBER INSTALLED IN ENERGY NETWORKS NORTH:</b>	0
<b>NUMBER INSTALLED IN ENERGY NETWORKS SOUTH:</b>	0
<b>REASON:</b>	Failure of Brush HSRSD tap changer due to the breakage of a taper pin leading to loss of drive to the diverter switches.
<b>STATUS IN INITIATING DNO:</b>	HSRSD tap changers must be put on fixed tap when access to compounds is required until the taper pin has been replaced with a spiral (roll) pin.
<b>SPEN APPLICATION:</b>	This SOP will not be applied within EnergyNetworks.
<b>UPDATE:</b>	
<b>REMEDIAL ACTION:</b>	None