



1. SCOPE

This document details the application of SOP 2007/0347/00 (Applicable to Hellerman 11KV heat shrink boots) issued by the Energy Networks Association.

2. ISSUE RECORD

This is a controlled maintained document.

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
June 2009	1	David Walker	

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Walker Senior Project Engineer	Alastair Ferguson Asset Risk Manager	Jim Sutherland Chief Engineer
	

4. SOP DETAILS

EQUIPMENT TYPE:	Hellerman 11KV heat shrink cable boots
ORIGINATING DNO	Central Networks
DATE:	02/11/2007
NUMBER INSTALLED IN ENERGY NETWORKS NORTH:	0
NUMBER INSTALLED IN ENERGY NETWORKS SOUTH:	0
REASON:	Failure of cable terminations, increasing number of occurrences of terminations found discharging.
STATUS IN INITIATING DNO:	a/ Live switchgear operation for fault localisation and supply restoration prohibited. b/ Switchgear operation prohibited and substation access restricted for units where audible discharged is present. All Hellerman heat shrink boot terminations to be replaced.
SPEN APPLICATION:	No units of this type on the SP T&D network. This SOP for information only.
UPDATE:	N/A
REMEDIAL ACTION:	None required.