

1. SCOPE

This document details the application of SOP 2008/0354/00 (Applicable to South Wales Switchgear, Tiger 350 RMU) issued by the Energy Networks Association.

2. ISSUE RECORD

This is a controlled maintained document.

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

Issue Date	Issue No	Author	Amendment Details
June 2009	1	David Walker	

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
David Walker Senior Project Engineer	Alastair Ferguson Asset Risk Manager	Jim Sutherland Chief Engineer
	

4. SOP DETAILS

EQUIPMENT TYPE:	South Wales Switchgear – Tiger 350 RMU
ORIGINATING DNO	Northern Ireland Electricity (NIE)
DATE:	11/08/2008
NUMBER INSTALLED IN ENERGY NETWORKS NORTH:	0
NUMBER INSTALLED IN ENERGY NETWORKS SOUTH:	0
REASON:	Failure within the main tank.
STATUS IN INITIATING DNO:	No live operation of outdoor SWS Tiger 350 RMU's shall be permitted.
SPEN APPLICATION:	No units of this type on the SP T&D network. This SOP for information only.
UPDATE:	N/A
REMEDIAL ACTION:	None required.