



**1. SCOPE**

This document details the application of SOP 2010/0362/00 (Applicable to Brush OL2 oil switches) issued by the Energy Networks Association.

**2. ISSUE RECORD**

This is a controlled maintained document.

All copies printed via the Intranet or photocopied will be deemed uncontrolled.

<b>Issue Date</b>	<b>Issue No</b>	<b>Author</b>	<b>Amendment Details</b>
April 2010	1	Alan MacGregor	

**3. ISSUE AUTHORITY**

<b>Author</b>	<b>Owner</b>	<b>Issue Authority</b>
Alan MacGregor Lead Engineer	Alastair Ferguson Asset Risk Manager	Pearse Murray Asset Strategy and Network Programmes Director  .....



#### 4. SOP DETAILS

<b>EQUIPMENT TYPE:</b>	Brush OL2 oil switches
<b>ORIGINATING DNO</b>	Central Networks
<b>DATE:</b>	07/08/2009
<b>NUMBER INSTALLED IN ENERGY NETWORKS NORTH:</b>	0
<b>NUMBER INSTALLED IN ENERGY NETWORKS SOUTH:</b>	0
<b>REASON:</b>	Disruptive failure of a Brush OL2 oil switch whilst being operated from ON to OFF to break a parallel. Oil expelled from the switch tank. Operator sustained minor injuries
<b>STATUS IN INITIATING DNO:</b>	As a precautionary measure a temporary operating restriction has been applied to Brush oil switches with "L" type operating mechanisms: "No live operation of the switch OFF/ON and ON/OFF".
<b>SPEN APPLICATION:</b>	No units of this type on the SP T&D network. This SOP is for information only.
<b>UPDATE:</b>	N/A
<b>REMEDIAL ACTION:</b>	None required.