

**1. SCOPE**

This document details the application of SOP 2011/0370/00 (Applicable to Schneider – EFU-NS & EFU-SHLD LV Cabinets at system voltages of .433kV) issued by the Energy Networks Association.

**2. ISSUE RECORD**

This is a **Controlled** document. The current version of **Controlled** document is held on the Energy Networks Intranet.

**It is your responsibility to ensure you work to the current version.**

Issue Date	Issue No.	Author	Amendment Details
October 2011	1	Mark Stewart	Initial issue

**3. ISSUE AUTHORITY**

Author	Owner	Issue Authority
Name: Mark Stewart Title: Lead Engineer Technical Risk	Name: Alastair Ferguson Title: Technical Risk Manager	Name: Jeff Hunt Title: Head of Asset Management.  ..... Date: .....

**4. REVIEW**

This is a **Controlled** document and shall be reviewed as dictated by business / legislative change but at a period of no greater than five years from the last issue date.

**5. DISTRIBUTION**

This document is not part of a Manual and does not have a maintained distribution list.

**6. CONTENTS**

<b>1. SCOPE.....</b>	<b>1</b>
<b>2. ISSUE RECORD.....</b>	<b>1</b>
<b>3. ISSUE AUTHORITY .....</b>	<b>1</b>
<b>4. REVIEW .....</b>	<b>1</b>
<b>5. DISTRIBUTION.....</b>	<b>2</b>
<b>6. CONTENTS .....</b>	<b>2</b>
<b>7. SOP DETAILS.....</b>	<b>3</b>

**7. SOP DETAILS**

<b>EQUIPMENT TYPE:</b>	<b>Schneider Electric – Shielded LV Cabinets Type EFU-NS &amp; EFU-SHLD</b>
<b>ORIGINATING COMPANY</b>	Severn Trent Water
<b>DATE:</b>	10/03/2011
<b>NUMBER INSTALLED IN ENERGY NETWORKS NORTH:</b>	0
<b>NUMBER INSTALLED IN ENERGY NETWORKS SOUTH:</b>	0
<b>REASON:</b>	Inadequate insulation and ingress protection level afforded in the basic design to allow intrusive access behind outgoing cable connection covers even when the respective circuit breaker is isolated.
<b>STATUS IN INITIATING COMPANY:</b>	No removal of internal covers whilst the source supply being isolated
<b>SPEN APPLICATION:</b>	No application. None of these units are installed.
<b>ADDITIONAL INFORMATION:</b>	N/A
<b>UPDATE:</b>	N/A
<b>REMEDIAL ACTION:</b>	N/A