

**All Cable Record enquiries should be addressed to:**

**SP Energy Networks (North)**

Data Management  
(Correspondence)  
55 Fullerton Drive  
Cambuslang  
Glasgow G32 8FD

t: 0141 567 4155 or 0141 567 4455

e: Requestforplansscotland  
@scottishpower.com

**SP Energy Networks (South)**

Data Management  
(Correspondence)  
North Cheshire Trading Estate  
Prenton Way  
Prenton  
Birkenhead CH43 3ET

t: 0151 609 2373

e: Requestforplansmanweb  
@manweb.co.uk

**All Cable Deviation Requests /Service Alterations enquiries should be addressed to:**

**SP Energy Networks (North)**

Customer Connections  
55 Fullerton Drive  
Cambuslang  
Glasgow G32 8FA

t: 0141 614 9997

**SP Energy Networks (South)**

Customer Connections  
PO Box 290  
Lister Drive  
Liverpool L13 7HJ

t: 0151 221 2110

**Emergency contact**

In an emergency, or if there is any damage to SP Energy Networks cables or plant, call the appropriate number:

**SP Energy Networks North**

Central & Southern  
Scotland

**0845 272 7999**

**SP Energy Networks South**

Cheshire,  
Merseyside  
& North Wales

**0845 272 2424**



# Case Study: Requirement for Flame Retardant, Personnel Protective Equipment



The above image highlights the serious consequences of contact with a high voltage cable; the operative concerned was not wearing flame retardant coveralls. The task for the operative was to excavate for the installation of lamp posts for a local authority, utility records on site were of a consultancy multi utility nature at not at an interpretable scale. The operative came into contact with the high voltage cable in the footpath with a compressor gun at a depth of 600mm, unfortunately on this occasion the operative was hospitalised with serious burns to his legs and head. Prior to undertaking excavations it is essential that the correct personal protective equipment required to undertake the task is supplied and utilised.

**Personal Protective Equipment (PPE) Is The Last Line In Defence. Prior To Carrying Out Excavations, Plan the Project**